F Rating - 2 Hr
T Rating - 1 Hr





Section A-A

1. **Wall Assembly —** Min 4-1/2 in. (114 mm) thick reinforced lightweight or normal weight 100-150 pcf (1600-2400 kg/m^3) concrete. Wall may also be constructed of any UL Classified **Concrete Blocks***. Max diam of opening is 4 in. (101 mm).

2. **Metallic Penetrants —** A max of two pipes or tubes installed eccentrically or concentrically within the opening. Annular space between penetrants and periphery of opening to be min 0 in. (point contact) to max 1-7/8 in. (48 mm). Separation between penetrants to be min 0 in. (point contact) to max 1/2 in. (13 mm). Penetrants to be rigidly supported on both sides of the wall. The following types and sizes of penetrants may be used:

A. **Copper Tubing —** Nom 1 in. (25 mm) diam (or smaller) Type L (or heavier) copper tubing.

B. **Copper Pipe —** Nom 1 in. (25 mm) diam (or smaller) Regular (or heavier) copper pipe.

C. **Steel Pipe —** Nom 1 in. (25 mm) (or smaller) Schedule 5 (or heavier) steel pipe.

D. **Iron Pipe —** Nom 1 in. (25 mm) (or smaller) cast or ductile iron pipe.

3. **Cables —** Max of two cable lengths installed eccentrically or concentrically within the opening. Annular space between penetrants and periphery of opening to be min 0 in. (point contact) to max 1 7/8 in. (48 mm). Separation between penetrants to be min 0 in. (point contact) to max 1/2 in. (13 mm). Penetrants to be rigidly supported on both sides of the wall. The following types and sizes of penetrants may be used:

A. **Cables —** Max 8/C No. 12 AWG multiconductor power and control cable with XLPE or PVC insulation and PVC jacket.

4. **Tube Insulation-Plastics+ —** Nom 3/4 in. (19 mm) thick (or less) acrylonitrile butadiene/polyvinyl chloride (AB/PVC) flexible foam furnished in the form of tubing. The tube insulation may be installed on a max of one pipe or tube. Annular space between the tube insulation and periphery of opening to be min 0 in. (point contact) to max 1-1/4 in. (32 mm). Space between insulated and uninsulated penetrants to be 0 in. (point contact) to max 1/4 in. (6 mm).

See Plastics (QMFZ2) category in the Plastics Recognized Component Directory for names of manufacturers. Any Recognized Component tube insulation material meeting the above specifications and having a UL 94 Flammability Classification of 94-5A may be used.

5. **Fill, Void or Cavity Materials* - Caulk —** Min 5/8 in. (16 mm) thickness of caulk applied within annulus, flush with both surfaces of wall assembly.
RECTORSEAL — MC 150+

*,+ Indicates such products shall bear the UL or cUL Certification Mark for jurisdictions employing the UL or cUL Certification (such as Canada), respectively.

Reprinted from the Online Certifications Directory with permission from UL. ©UL LLC