


ANSI/UL1479 (ASTM E814)	CAN/ULC S115
F Rating — 2 Hr	F Rating — 2 Hr
T Rating — 2 Hr	FT Rating — 2 Hr
L Rating At Ambient — Less Than 1 CFM/sq ft	FH Rating — 2 Hr
L Rating At 400 F — Less Than 1 CFM/sq ft	FTH Rating — 2 Hr



System tested with a pressure differential of 50 Pa between the exposed and the unexposed surfaces with the higher pressure on the exposed side.

1. **Floor or Wall Assembly** — Min 4-1/2 in. (114 mm) thick reinforced lightweight or normal weight (100-150 pcf or 1600-2400 kg/m³) concrete. Max diam of opening is 3 in. (76 mm).
2. **Through Penetrant** — Nom 2 in. (51 mm) diam (or smaller) Schedule 40 solid core XFR coated polyvinyl chloride (PVC) pipe for use in closed (process or supply) or vented (drain, waste or vent) piping systems. Pipe centered within the firestop system with a nom annular space of 5/16 in. (8 mm). Pipe to be rigidly supported on both sides of floor or wall assembly. 3. The firestop system consisted of the following:
 - A. **Fill, Void or Cavity Materials* - Wrap Strip** — Nom 1/4 in. (6 mm) thick intumescent material supplied in 2 in. (51 mm) wide strips. Min one layer of wrap strip wrapped tightly around the nonmetallic penetrant, held in position with tape and recessed min 1/2 in. (13 mm) to max 2-1/4 in. (57 mm) from the bottom of the floor or both surfaces of the wall.
RECTORSEAL — [Metacaulk Wrap Strip](#)
 - B. **Fill, Void or Cavity Material* - Sealant** — Min 1/4 in. (6 mm) thickness of caulk applied within annulus, flush with the top surface of floor or both surfaces of wall.
RECTORSEAL — [Metacaulk 1000](#) or [Metacaulk 350i](#)

*,+ Indicates such products shall bear the UL or cUL Certification Mark for jurisdictions employing the UL or cUL Certification (such as Canada), respectively.

Reprinted from the Online Certifications Directory with permission from UL. ©UL LLC