



A CSW Industrials Company

GENERAL CERTIFICATE OF COMPLIANCE

DESCRIPTION:

METACAULK® FIRESTOPPING PRODUCTS

METACAULK® MC 150+ FIRESTOP SEALANT
METACAULK® 350i FIRESTOP SEALANT
METACAULK® 835+ SILICONE SEALANT
METACAULK® 835+ SILICONE SPRAY
METACAULK® 950 FIRESTOP SEALANT
METACAULK® 1000 FIRESTOP SEALANT
METACAULK® 1200
METACAULK® BLAZESEAL™
METACAULK® BOX GUARD™
METACAULK® COMPOSITE SHEET
METACAULK® COVER GUARD™
METACAULK® FIRE-RATED MORTAR
METACAULK® FIRESTOP PILLOW
METACAULK® INDUSTRIAL CABLE COATING
METACAULK® INTUMESCENT SLEEVE
METACAULK® JOINT STRIP
METACAULK® PIPE COLLAR
METACAULK® CID
METACAULK® PUTTY STICK & PUTTY PAD
METACAULK® WRAP STRIP
FLAMESAFE® BAGS
FLAMESAFE® FS 900+ SEALANT
RECTORSEAL® BLAZE FOAM™
RECTORSEAL® SMOKE AND ACOUSTIC SEALANT

THESE PRODUCTS ARE TESTED ACCORDING TO ONE OR MORE OF THE FOLLOWING STANDARDS:

U.L. 263 - FIRE TESTS OF BUILDING CONSTRUCTION AND MATERIALS
U.L. 1479 - FIRE TESTS OF THROUGH-PENETRATION FIRESTOPS
U.L. 2079 - TESTS FOR FIRE RESISTANCE OF BUILDING JOINT SYSTEMS
ASTM E-84 (UL 723) - SURFACE BURNING CHARACTERISTICS OF BUILDING MATERIALS
ASTM E-814 - FIRE TESTS OF THROUGH-PENETRATION FIRESTOPS
ASTM E-2307 - METHOD FOR DETERMINING FIRE RESISTANCE OF PERIMETER FIRE BARRIERS
IEEE 1202 - FLAME-PROPAGATION TESTING OF WIRE & CABLE



A CSW Industrials Company

ALL PRODUCTS CONTAIN NO ASBESTOS OR PCB'S AND ARE CONSIDERED V.O.C. COMPLIANT.

A handwritten signature in dark ink, appearing to read "Eva Ackerman", written over a horizontal line.

EVA ACKERMAN PH.D
VICE PRESIDENT OF RESEARCH & TECHNOLOGY

A handwritten signature in dark ink, appearing to read "Terry Gossett", written over a horizontal line.

TERRY GOSSETT
TECHNICAL SERVICES

SUBSCRIBED AND SWORN TO BEFORE ME THIS 22nd DAY OF January 2020.

A handwritten signature in dark ink, appearing to read "Melissa Schoenberg", written over a horizontal line.

MELISSA SCHOENBERG
NOTARY IN AND FOR THE STATE OF TEXAS
COUNTY OF HARRIS
MY COMMISSION EXPIRES: OCTOBER 25, 2023

