


F Rating — 3 Hr T Rating — 0 Hr



- 1. Floor or Wall Assembly Min 4-1/2 in. (114 mm) thick reinforced lightweight or normal weight (100<u>150</u> pcf or 1600-2400 kg/m³) concrete. Wall may also be constructed of any UL ClassifiedConcrete Blocks*. Max diam of opening is 6 in. (152 mm). See Concrete Blocks (CAZT) category in the Fire Resistance Directory for names of manufacturers.
- 2. **Through Penetrants** One metallic pipe, conduit or tubing to be either concentrically or eccentrically within the firestop system. The annular space between pipes, conduits or tubing and periphery of opening shall be min 0 in. (point contact) to max 1-1/2 in. (38 mm). Pipe, conduit or tubing to be rigidly supported on both sides of floor or wall assembly. The following types and sizes of metallic pipes, conduits or tubing may be used:
 - A. Steel Pipe Nom 8 in. (203 mm) diam (or smaller) Schedule 10 (or heavier) steel pipe.
 - B. Iron Pipe Nom 4 in. (102 mm) diam (or smaller) cast or ductile iron pipe.
 - C. Conduit Nom 4 in. (102 mm) diam (or smaller) steel electrical metallic tubing or steel conduit.
- 3. **Firestop System** The firestop system shall consist of the following:
 - A. **Packing Material** Min 3-3/4 in. (95 mm) thickness of min 4 pcf (64 kg/n³) mineral wool batt insulation firmly packed into opening as a permanent form. Packing material to be recessed from bottom surface of floor or from either surface of wall to accommodate the required thickness of fill material.
 - B. Fill, Void or Cavity Material* Caulk Min 3/4 in. (19 mm) thickness of fill material applied within the annulus, flush with bottom surface of floor or with either surface of wall. Min 1/4 in. (6 mm) diam bead of caulk applied to the penetrant/concrete interface at the point contact location on the bottom surface of floor or either surface of wall.

 RECTORSEAL Metacaulk 350i

Reprinted from the Online Certifications Directory with permission from UL. ©UL LLC

^{*,+} Indicates such products shall bear the UL or cUL Certification Mark for jurisdictions employing the UL or cUL Certification (such as Canada), respectively.